

KARL F. DEAN  
MAYOR



## METROPOLITAN GOVERNMENT OF NASHVILLE AND DAVIDSON COUNTY

DEPARTMENT OF WATER AND SEWERAGE SERVICES  
STORMWATER DIVISION  
DEVELOPMENT REVIEW  
800 2ND AVENUE, SOUTH  
NASHVILLE, TENNESSEE 37210

February 22, 2013

Skip Short  
VP-Sales, Eastern Region  
KriStar Enterprises, Inc.  
4020 Riverclub Drive  
Cumming, GA 30041

RE: Metro Water Services Proprietary BMP Approval  
FloGard Perk Filter by Kristar Enterprises

Dear Mr. Short,

Metro Water Services (MWS) is in the process of updating our approved listing of proprietary BMPs for use in Metro Nashville and Davidson County. The July 6<sup>th</sup>, 2010 submittal and follow-up letter dated January 28<sup>th</sup> 2011 are being evaluated by MWS technical staff for full-treatment status (80% TSS removal). The Stormwater Management Manual, Volume 1 – Regulations Section 7.6 allows for the use of proprietary BMPs as Limited Application BMPs. Proprietary devices must be approved by MWS before they can be considered for use in Metro through an application and acceptance process. Metro Stormwater has adopted an interim policy which includes the following:

*MWS will also accept current proprietary BMP certifications from the New Jersey Department of Environmental Protection (NJDEP). MWS will consider the results of other verification systems and review them on a case by case basis.*

Since the FloGard Perk Filter has not yet been evaluated or certified by NJDEP, the application submitted will be evaluated for compliance with the TARP Protocol (Tier II) for Stormwater BMP Demonstrations and the NJDEP Protocol for Manufactured Filtration Devices. Please submit additional information including the report prepared for WDOE in compliance with TAPE procedures. Also, if an application has been submitted to NJCAT and/or NJDEP please submit a copy of application, reports, verification, calculations and other relevant information.



Metro Water Services complies with the Americans with Disabilities Act.  
For additional information contact Joseph A. Estes, Sr., 1600 2<sup>nd</sup> Avenue  
North, Nashville, TN 37208-2206; telephone 615-862-4862.

Skip Short  
February 22, 2013  
Perk Filter  
Page 2 of 2

A copy of the MWS Stormwater Management Manual Interim Policy is attached to this letter. Additional information regarding the Stormwater Management Regulations may be found at [www.nashville.gov](http://www.nashville.gov). If you have any questions regarding the above information, please contact Laura Jones with Stormwater Development Review by phone, 615-880-3832, or email, [laura.jones2@nashville.gov](mailto:laura.jones2@nashville.gov).

Sincerely,

A handwritten signature in blue ink that reads "Roger D. Lindsey". The signature is fluid and cursive, with the first name "Roger" being the most prominent.

Roger D. Lindsey, P.E., CFM  
Program Manager - Development Review Section  
Metro Water Services - Stormwater Division  
800 2nd Ave South  
P.O. Box 196300  
Nashville, TN 37219-6300  
Phone: 615-862-4706  
Fax: 615-862-4715

LTJ

Enclosure:

MWS Stormwater Management Manual Interim Policy